WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69089
Permit No.
Basin 212

NOTICE OF INTENT NO. 11972

1. OWNER Western Summit
MAILING ADDRESS 5470 Valley Highway
ADDRESS AT WELL LOCATION 200 Athens Av Henderson NV

2. LOCATION SE ¼ ¼ Sec. 36 T. 21 N/S R. 62 E. Clark County
PERMIT NO. DW1007 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
Dewatering
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other Buckit Rig

6. Clarifier LITHOLOGIC LOG

Well 3#

Material	Water Strata	From	To	Thickness
Sand & Gravel w/Cobel		0	20	20
Sandy Clay w/ Coble		20	30	10
Sandy Clay w/ Gravel		30	40	10
White Clay		40	50	10

RECEIVED
MAY 26 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 5-24, 1993
Date completed 5-24, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 50 Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)
24" Inches From 0 Feet To 50 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12			0	50

Perforations:
Type perforation SAW CUT
Size perforation .040
From 20 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 50 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Foot Hills Eng (Contractor)
Address 905 E 3rd St (Contractor)
Corona Cal.
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562
Signed Chuck W Lewell
By driller performing actual drilling on site or contractor
Date 5-24

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627