

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 11972

1. OWNER Western Summit ADDRESS AT WELL LOCATION 200 Athens Av
 MAILING ADDRESS 5470 Valley Highway Henderson NV
Denver Co
 2. LOCATION SE 1/4 1/4 Sec. 36 T. 21 N(S)R. 62 E. CLARK County
 PERMIT NO. 1007 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other... Drill bit

6. Clarifier LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SAND & GRAVEL</u>		<u>0</u>	<u>15</u>	<u>15</u>
<u>GRAVEL & SAND</u>		<u>15</u>	<u>35</u>	<u>20</u>
<u>BROWN CLAY</u>		<u>35</u>	<u>38</u>	<u>3</u>
<u>WHITE CLAY W/ SAND</u>		<u>38</u>	<u>50</u>	<u>12</u>

8. WELL CONSTRUCTION
 Depth Drilled 50 Feet Depth Cased 50 Feet
 HOLE DIAMETER (BIT SIZE)
 From 24 Inches To 50 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12</u>			<u>0</u>	<u>50</u>

Perforations:
 Type perforation SAW CUT
 Size perforation 1040
 From 20 feet to 50 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 0 feet to 50 feet

9. WATER LEVEL
 Static water level 20 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Foot Hills Eng Contractor
 Address 905 E 3rd ST Contractor
Corona Cal.
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 1567
 Signed Chuck V. Sewell
 By driller performing actual drilling on site or contractor
 Date 5-24

Date started 5-24, 1993
 Date completed 5-24, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

RECEIVED

MAY 26 1993

Div. of Water Resources
 Branch Office - Las Vegas NV