WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69093
Permit No.
Basin 0-16

NOTICE OF INTENT NO. 34915

1. OWNER John Johnson
MAILING ADDRESS 870 Sherman
Reno, NV 89506

ADDRESS AT WELL LOCATION
1905 Scenic ct, Fernley, NV 89408

2. LOCATION NE 1/4 SE 1/4 Sec. 36 T 20N N/S R 25E E Lyon County
PERMIT NO. _____ Issued by Water Resources | 21-307-02 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	45	45
Brown Clay and sand		45	240	195
Gray Clay		240	300	60
Gravel & Sand	X	300	490	190

97 JAN 15 AM 11:12
STATE ENGINEER'S OFFICE

Date started 10-9, 1996
Date completed 10-13, 1996

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 490 Feet Depth Cased 490 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	490	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	490

Perforations:
Type perforation Mill Cut
Size perforation 1/8
From 0- 470 feet to 490 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 490 feet

9. WATER LEVEL
Static water level 340 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 11-15-96