

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 69100
 Permit No. _____
 Basin 101



NOTICE OF INTENT NO. 30728

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Carl Sandgren Construction ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 692 1565 Golden parkway, Fallon, NV 89406
Fallon, NV 89407

2. LOCATION NW 1/4 SW 1/4 Sec. 19 T 19N N/S R 29E E Churchill County
 PERMIT NO. _____ Issued by Water Resources 008-312-66 Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Brown Clay		5	8	3
Brown Sand		8	30	22
Gray Silt		30	36	6
Gray sand		36	41	5
Black Clay		41	59	18
Gray Sand		59	74	15
Gray Clay		74	78	4
Brown Sand	X	78	87	9

8. WELL CONSTRUCTION
 Depth Drilled 87 Feet Depth Cased 87 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 Inches 0 Feet 87 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	87

Perforations:
 Type perforation Mill Cut
 Size perforation 1/8 x 3"

From 84 feet to 87 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 80 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 80 feet to 87 feet

9. WATER LEVEL
 Static water level 9 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Parsons Drilling, Inc. Contractor
 Address P.O. Box 1265 Contractor
Fallon, NV 89407-1265
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1696
 Signed Deirdre Parsons
 By driller performing actual drilling on-site or contractor
 Date 8-1-97

Date started 7/28/97, 19____
 Date completed 7/28/97, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>		<u>1 hr.</u>

RECEIVED
 97 AUG -8 AM 11:21
 STATE ENGINEER'S OFFICE