WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

**PRINT OR TYPE ONLY**
**DO NOT WRITE ON BACK**

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69105
Permit No.
Basin 101

NOTICE OF INTENT NO. 36724

1. OWNER Dwayne South
MAILING ADDRESS P.O. Box 11173
Reno, NV 89510

ADDRESS AT WELL LOCATION
830 Joel way, Fallon, NV 89406

2. LOCATION NW 1/4 NE 1/4 Sec. 6 T 18N N/S R 29E E Churchill County
PERMIT NO. (Issued by Water Resources) 006-691-48 (Parcel No.) Evergreen Estates (Subdivision Name)

**3. WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

**4. PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

**5. WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

**6. LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil | | 0 | 5 | 5 |
| Brown Clay | | 5 | 15 | 10 |
| Fine Brown Sand | | 15 | 30 | 15 |
| Gray Sand | | 30 | 55 | 25 |
| Black Clay | | 55 | 62 | 7 |
| Brown Sand | | 62 | 95 | 33 |
| Brown Clay | | 95 | 97 | 2 |
| Brown Sand | | 97 | 110 | 13 |
| Brown Clay | | 110 | 117 | 7 |
| Brown Sand | X | 117 | 130 | 13 |

RECEIVED 97 AUG -8 AM 11:21 STATE ENGINEER'S OFFICE

Date started 6/10/97, 19__
Date completed 6/10/97, 19__

**7. WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20 | | 1 hr. |

**8. WELL CONSTRUCTION**
Depth Drilled 130 Feet Depth Cased 130 Feet

**HOLE DIAMETER (BIT SIZE)**

| | | From | | To | |
|---|---|---|---|---|---|
| 10 | Inches | 0 | Feet | 130 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

**CASING SCHEDULE**

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.92 | .188 | 0 | 130 |
| | | | | |
| | | | | |

**Perforations:**
Type perforation Mill Cut
Size perforation 1/8 X 3"
From 127 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 130 feet

**9. WATER LEVEL**
Static water level 11 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

**10. DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons
By driller performing actual drilling on-site or contractor

Date 7-25-97