WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69118
Permit No.
Basin 040

NOTICE OF INTENT NO. 30582

1. OWNER Jeff Williams
MAILING ADDRESS 163-5 Osino
Elko, NV 89801

ADDRESS AT WELL LOCATION N. Side of So. 8th St. between Chippawe & Zuni

2. LOCATION NW ¼ SW ¼ Sec. 9 T 35 (N)/S R 56 E Elko County
PERMIT NO. (Issued by Water Resources) | 35055-06 (Parcel No.) | MVR #3 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Topsoil		0	5	5
Silty Gravel & Boulders		5	13	8
Brown Clay		13	25	12
Brown Sandy Clay		25	90	65
Mild Brown Siltstone		90	185	95
Brown Clay		185	205	20
Siltstone & Pea Gravel	X	205	255	50

Date started 3-29, 1996
Date completed 4-5, 1996

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [XX] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Blow Test	30		3-1/2

8. WELL CONSTRUCTION
Depth Drilled 255 Feet Depth Cased 255 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10-5/8 Inches	0 Feet	50 Feet
9-7/8 Inches	50 Feet	255 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13	.188	+1-1/2	255

Perforations:
Type perforation Millslot
Size perforation 3/16 x 3
From 235 feet to 255 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 255 feet

9. WATER LEVEL
Static water level 92 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hackworth Drilling Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 4-11-96

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627