WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69120
Permit No.
Basin 049 I

NOTICE OF INTENT NO. 30583

1. OWNER Jeff Williams
MAILING ADDRESS 163-5 Osino
Elko, NV 89801

ADDRESS AT WELL LOCATION So. Side of So. 4th St. between Chippewa & Zuni Ave.

2. LOCATION NW ¼ NW ¼ Sec. 9 T. 35 (N) S R. 56 E. Elko County
PERMIT NO. (Issued by Water Resources) 35-040-02 (Parcel No.) MVR #3 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy & Clay		0	19	19
Pea Gravel & Sandy Clay		19	80	61
Siltstone & Pea Gravel		80	145	65
Green Silt/Brown Clay		145	205	60
Siltstone & Pea Gravel		205	250	45
Layers of Siltstone & Fractured Volcanic Rock	X	250	300	50

Date started 4-9, 19 96
Date completed 4-10, 19 96

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Blow Test	40		3

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10-5/8 Inches		0 Feet	50 Feet
9-7/8 Inches		50 Feet	300 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13	.188	+2	300

Perforations:
Type perforation Millslot
Size perforation 3/16 x 3 x 6 Row
From 280 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 300 feet

9. WATER LEVEL
Static water level 155 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hackworth Drilling Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 4-16-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627