WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69130
Permit No. 56762
Basin 177

NOTICE OF INTENT NO. 20526

1. OWNER Emerald Huldermann #1
MAILING ADDRESS Riverside Calif
ADDRESS AT WELL LOCATION Clover Valley So. of Wells, Nv

2. LOCATION SE ¼ SW ¼ Sec. 5 T. 34 N/S R. 63 E. Elko County
PERMIT NO. ~~56884~~ 56762 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	
Gray & Broken Rock		2	65	
Broken Granite	x	65	100	
Solid Granite		100	112	
Layers Solid & Broken		112	124	
Hard Green Granite	x	124	132	
Layers Broken Granite		132	159	
Hard gray & green Rock		159	167	
Solid Granite		167	180	
Solid Granite		180	240	

Post-it® Fax Note 7671 | Date 11/2/95 | # of pages ▶ 1
To LINDA REYNOLDS | From RAY Reynolds
Co./Dept. | Co.
Phone # | Phone #
Fax # 753-7693 | Fax #

Date started May 7, 1993
Date completed Feb, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
80	?	2

8. WELL CONSTRUCTION
Depth Drilled 230 Feet Depth Cased 230 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
16 Inches	0 Feet	Feet
12 Inches	172 Feet	240 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12		.250	+1	172
10		.250	168	230

Perforations:
Type perforation Factory Milled
Size perforation 3/16 x 3
From 51 feet to 230 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 51 feet to 170 feet

9. WATER LEVEL
Static water level 51 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RD Reynolds Drilling (Contractor)
Address Wells, Nevada (Contractor)

Nevada contractor's license number issued by the State Contractor's Board C14410
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1390
Signed [signature] By driller performing actual drilling on site or contractor
Date 8-20-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627