

OFFICE USE ONLY
 Log No. 09131
 Permit No. _____
 Basin _____
 091
 36247
 22347

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22347

1. OWNER Jake Huber ADDRESS AT WELL LOCATION 417 Tenaya Hill
 MAILING ADDRESS P.O. Box 279 Verdi, NV 89439

2. LOCATION NW 1/4 SE 1/4 Sec. 18 T. 19 N'S R. 18 East Washoe County
 PERMIT NO. 038-213-17 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cobble Rocks		0	20	20
Brown clay soft		20	34	14
Black granite hard		34	50	16
Brown & green clay sticky		50	80	30
Gray sticky clay		80	110	30
Gray clay stone soft		110	135	25
Black clay stone soft	X	135	155	20
Gary clay stone soft	X	155	170	15
T.D. 170'				

8. WELL CONSTRUCTION
 Depth Drilled 170 Feet Depth Cased 170 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 170 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.92	.188	1 1/2	170

Perforations:
 Type perforation Factory Sawn
 Size perforation 3/32 X 3
 From 150 feet to 170 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 170 feet to 100 feet

9. WATER LEVEL
 Static water level 80 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service, Inc. Contractor
 Address 1800 1/2 Frazer Ave. Contractor
Sparks, NV 89431

Nevada contractor's license number issued by the State Contractor's Board 35387-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509T-1
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date April 6, 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12		2 hours