

OFFICE USE ONLY
 Log No. 09133
 Permit No. _____
 Basin. 091

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33248

1. OWNER Jake Huber ADDRESS AT WELL LOCATION 417 Tenaya Lane
 MAILING ADDRESS P.O. Box 279 Verdi, NV 89439
 2. LOCATION NW 1/4 SE 1/4 Sec. 18 T. 19 Q/S R. 18 East Washoe County
 PERMIT NO. 038-213-17 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Set up, Trip in tag bottom, 220' casing will not pull out preforate 4 rows from 50' to 200'				
Install trimie pipe to 200' pump Approx 12,300 lbs of neat ceament to surface cut off casing 1 ft below finished grade				
Abandon T.D. 200'				

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10.79	.156	+1	200

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal In Place
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 100 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. Pump & well Service, Inc. Contractor
 Address 1800 1/2 Frazer Ave. Contractor
Sparks, NV 89431
 Nevada contractor's license number issued by the State Contractor's Board 35387-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509T-1
 Signed Larry Welch
 By driller performing actual drilling on site or contractor
 Date April 6, 1997

Date started April 4, 1997
 Date completed April 4, 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)