

OFFICE USE ONLY
 Log No. 69168
 Permit No. 90
 Basin 90

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38321

1. OWNER Shell (S-4) ADDRESS AT WELL LOCATION 1001 Village Blvd
 MAILING ADDRESS 898 N. Tahoe Blvd on south side of Tahoe St.
Incline Village Nev. Incline Village - Nev.
 2. LOCATION SW 1/4 NE 1/4 Sec. 15 T. 16 S. R. 18 E. Washoe County
 PERMIT NO. NA Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Permeation Hammer

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>75% of Ben Kiveto</u>		<u>0</u>		
<u>Coarse Sand 25% gravels</u>		<u>22</u>	<u>22</u>	
<u>70% Silty Sand</u>		<u>22</u>		
<u>30% Coarse Sand to</u>			<u>53</u>	<u>31</u>
<u>gravel some Boulders</u>				
<u>65% Fine to Coarse</u>		<u>53</u>		
<u>Sand 35% Fine to</u>			<u>93</u>	<u>40</u>
<u>Coarse gravels</u>	<u>86'</u>			
<u>some Boulders</u>		<u>93</u>		
<u>60% Silty Sand to Coarse</u>		<u>93</u>		
<u>Sand 40% Fine to</u>			<u>110</u>	<u>17</u>
<u>Coarse gravels @</u>				
<u>some Boulders</u>				

8. WELL CONSTRUCTION
 Depth Drilled 110 Feet Depth Cased 110 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10" Inches To 110 Feet
 From 0 Feet To 110 Feet
 From 0 Inches To 110 Feet
 From 0 Inches To 110 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Pi. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>	<u>PVC</u>	<u>sch. 40</u>	<u>0</u>	<u>75</u>

Perforations:
 Type perforation slot
 Size perforation .020
 From 75 feet to 110 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 108 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 71 feet to 110 feet

9. WATER LEVEL
 Static water level 85.6 feet below land surface
 Artesian flow NA G.P.M. NA P.S.I.
 Water temperature NA °F Quality NA

Date started 9-9 1997
 Date completed 9-10 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>None</u>			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Layne Christensen Contractor
 Address 11001 Estivanda Ave Contractor
Pentona, Ca 92337
 Nevada contractor's license number #0019100 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources #1408
 Signed Steve Phelan By driller performing actual drilling on site or contractor
 Date 9/29/97