WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69170
Permit No.
Basin 90

NOTICE OF INTENT NO. 38375

1. OWNER Shell (5-6)
MAILING ADDRESS 898 N. Tahoe Blvd
Incline Village - Nev.
ADDRESS AT WELL LOCATION Old Texaco
899 N. Tahoe Blvd
Incline Village - Nev

2. LOCATION SW ¼ NE ¼ Sec. 15 T. 16 N/S R. 18 E. Washoe County
PERMIT NO. NA (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Percussion Hammer

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
60% Fine Sand 25% silt 15% Fine gravel		0	7	7
60% Fine to Coarse sand 40% Fine to Coarse gravel		7	46	39
70% Fine to Coarse Sand 30% Fine to Coarse gravel		46	55	9
70% Fine to Coarse sand 20% Fine to Coarse gravel 10% Boulder		55	72	
60% Fine to Med Sand 30% Boulder 10% Fine to Coarse gravel	100'	72	105	
60% Fine to med Sand 20% silt 20% Fine gravel		105	116	11

Date started 9-11, 1997
Date completed 9-12, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NONE		

8. WELL CONSTRUCTION
Depth Drilled 116 Feet Depth Cased 116 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10" Inches	0 Feet	116 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	PVC	Sch. 40	0	81

Perforations:
Type perforation slot
Size perforation .020
From 81 feet to 116 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 75
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 78 feet to 116 feet

9. WATER LEVEL
Static water level 99.65 feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature NA °F Quality NA

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cayne Christensen (Contractor)
Address 11001 Etiwanda Ave (Contractor)
Fontana - CA 92337
Nevada contractor's license number issued by the State Contractor's Board #0019101
Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1468
Signed Steve Johnson (By driller performing actual drilling on site or contractor)
Date 10/1/97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627