WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK 27ACD

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 109204
Permit No.
Basin 093

I

NOTICE OF INTENT NO. 33896

1. OWNER BOB & DORIS SMITH
MAILING ADDRESS 2820 Wade Street
Minden, Nevada 89423

ADDRESS AT WELL LOCATION 1339 Antelope Valley Road
Reno, Nevada 89506

2. LOCATION SW ¼ NE ¼ Sec. 27 T 22N N/S R 19 E Washoe County
PERMIT NO. (Issued by Water Resources) 079-450-46 (Parcel No.) Antelope Valley Red Rock Est #3 (Subdivision Name) part 3

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Soft fine brown sand		1	10	9
Brown sandy clay		10	35	25
Brown sandy clay with smaller boulders		35	56	21
Brown sandy clay		56	122	66
Soft zone, brown sand NO WATER		122	141	19
Brown sandy clay		141	155	14
Soft zone, medium brown sand	X	155	169	14
Brown sandy clay		169	183	14
Medium to coarse sands	X	183	201	18
Brown sandy clays		201	205	4

Date started 5-7-97, 19
Date completed 5-8-97, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		

8. WELL CONSTRUCTION
Depth Drilled 205 Feet Depth Cased 205 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	205 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	205

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 205 feet

9. WATER LEVEL
Static water level 122 feet below land surface
Artesian flow G.P.M. 25 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date May 14, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627