WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 09205
Permit No.
Basin 93

NOTICE OF INTENT NO. 37122

1. OWNER MICAH & LESSLIE KENNEDY
MAILING ADDRESS 4947 Stoltz
Reno, Nevada 89506

ADDRESS AT WELL LOCATION
1270 Serpentine
Reno, Nevada 89506

2. LOCATION ~~NW~~ SW ¼ SE ¼ Sec. 15 T. 22N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 079-049-23 (Parcel No.) Antelope Valley Red Rock Est # 2000 per 4 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay w/decomposed granite		0	9	9
Soft zone, sandy clay		9	11	2
Brown sandy clay with decomposed granite		11	39	28
Soft zone		39	41	2
Weathered granite with clay streaks		41	62	21
Soft zone		62	64	2
Weathered granite		64	78	14
Brown sandy clay with decomposed granite		78	106	28
Weathered gray granite		106	156	50
Fracture rock	X	156	165	9
Gray hard granite		165	185	20
Soft zone	X	185	186	1
Gray granite w/gray clay		186	198	12
Gray granite		198	211	13
Soft granite with clay streaks		211	221	10
Gray rock granite		221	225	4

Date started 9-18-97, 19
Date completed 9-19-97, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
23		

8. WELL CONSTRUCTION
Depth Drilled 225 Feet Depth Cased 225 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	50 Feet
8 5/8 Inches	50 Feet	225 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	225

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 160 feet to 180 feet
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 225 feet

9. WATER LEVEL
Static water level 146 feet below land surface
Artesian flow G.P.M. 23 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed Gary N. Hedman (By driller performing actual drilling on site or contractor)
Date September 23, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627