

OFFICE USE ONLY
 Log No. 12920
 Permit No. _____
 Basin 82
 NOTICE OF INTENT NO. 37091

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER DARCY BUSCH ADDRESS AT WELL LOCATION 635 Alamosa
 MAILING ADDRESS 145 7th Avenue Sparks, Nevada 89436
Sun Valley, Nevada 89433
 2. LOCATION NW 1/4 NW 1/4 Sec. 18 T. 21N N/S R. 21 E. Washoe County
 PERMIT NO. 076-360-53 Spanish Springs Subdivision Name
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Weathered granite		1	27	26
Rusty decomposed granite		27	29	2
Weathered granite		29	73	44
Soft rusty granite		73	86	13
Hard weathered granite		86	243	157
White granite		243	278	35
Soft rusty granite with clay streaks		278	297	19
Hard weathered granite		297	332	35
Hard white granite		332	444	112
Fracture rock (NO WATER)		444	447	3
White granite with clay streaks		447	469	22
Gray hard granite		469	592	123
Fracture (NO WATER)		592	593	1
Gray granite		593	621	28
Fracture rock	X	621	638	17
Gray granite		638	650	12

8. WELL CONSTRUCTION
 Depth Drilled 650 Feet Depth Cased 650 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 650 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	650

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 600 feet to 640 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 650 feet

9. WATER LEVEL
 Static water level 561 feet below land surface
 Artesian flow _____ G.P.M. 25 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date October 9, 1997

Date started 10-1-97, 19____
 Date completed 10-7-97, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		