

WHITE-DIVISION OF WATER RESOURCES
 CANARY-CLIENT'S COPY
 PINK-WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 69209
 Permit No. _____
 Basin. 085
 NOTICE OF INTENT NO. 26240

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER WASHOE COUNTY
 MAILING ADDRESS P.O. BOX 11130
RENO, NEVADA 89520
 ADDRESS AT WELL LOCATION SPANISH SPRINGS VALLEY
 2. LOCATION NE $\frac{1}{4}$ NW $\frac{1}{4}$ Sec 34 T. 21 NSR 20 E. WASHOE County
 PERMIT NO. M/O-1067 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND GRAVEL		0	40	40
SAND - CLAYS		40	60	20
SAND - GRAVEL		60	70	10
BROWN CLAY	STATIC	70	90	20
SANDY CLAYS		90	100	10
CLAYS - SOME SAND		100	130	30
GREY CLAY - SOME SAND		130	226	96
CLAY - SAND		226	250	24
GRAY CLAY - SAND		250	290	40
SAND GRAVEL		290	300	10
GRAY CLAY		300	330	30
SAND - GRAVEL		330	340	10
GRAY CLAY		340	350	10
SAND GRAVEL		350	400	50
SAND GRAVEL - SOME CLAYS		400	450	50
SAND GRAVEL		450	520	20
SAND - CLAYS		520	620	100

8. WELL CONSTRUCTION
 Depth Drilled 620 Feet Depth Cased 523 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12-1/4 Inches 0 Feet 20 Feet
6-1/4 Inches 20 Feet 620 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8-3/4	<u>28.55</u>	.312	0	20
2.376	<u>5.02</u>	.210	+2	271

Perforations:
 Type perforation SLOT
 Size perforation 3/32
 From 271 feet to 523 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 130 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 620 feet to 130 feet

9. WATER LEVEL
 Static water level 76 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature 95 °F Quality GOOD

Date started FEBRUARY 10 1997
 Date completed FEBRUARY 12 1997

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
30			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name LANG EXPLORATORY DRILLING Contractor
 Address 2286 WEST 1500 SOUTH Contractor
SALT LAKE CITY, UTAH 84104
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1410
 Signed JOHN VIERGUTZ *John Viergutz*
 By driller performing actual drilling on site or contractor
 Date FEBRUARY 12, 1997