DSMW-5

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69210
Permit No.
Basin 085

NOTICE OF INTENT NO. 26241

1. OWNER WASHOE COUNTY
MAILING ADDRESS P.O. BOX 11130
RENO, NEVADA 89520

ADDRESS AT WELL LOCATION
SPANISH SPRINGS VALLEY

2. LOCATION NE ¼ NW ¼ Sec. 34 T 21 (N)S R 20 E WASHOE County
PERMIT NO. M/O-1067 Issued by Water Resources | N/A Parcel No. | N/A Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND - GRAVEL		0	40	40
SAND - GRAVEL		40	220	180
SAND - KIFE		220	225	5
GRAVEL - START CLAYS				
CLAYS - GRAY		225	405	180
SAND		405	412	7
CLAYS - SAND STRINGERS		412	560	148
SAND GRAVELS		560	640	80
CLAYS - KIFE SAND		640	680	40

Date started FEBRUARY 7, 1997, 19
Date completed FEBRUARY 10, 1997, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
45		

8. WELL CONSTRUCTION
Depth Drilled 680 Feet Depth Cased 670 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12-1/4 Inches	0 Feet	20 Feet
6-1/4 Inches	20 Feet	680 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8-3/4	28.55	.312	0	20
2.376	5.02	.210	+2	460

Perforations:
Type perforation SLOT
Size perforation 3/32
From 460 feet to 670 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured

Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 680 feet to 105 feet

9. WATER LEVEL
Static water level 42 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 85 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1410

Signed JOHN VIERGUTZ John Viergutz
By driller performing actual drilling on site or contractor
Date FEBRUARY 10, 1997

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627