

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35233

1. OWNER Joyce A. Hines ADDRESS AT WELL LOCATION 451 E Lamarche  
 MAILING ADDRESS Silver Springs, NV.  
 2. LOCATION NW 1/4 SW 1/4 Sec 9 T 17 N/S R 25 E County Hardey  
 PERMIT NO. 17-173-14 Parcel No. \_\_\_\_\_ Subdivision Name Hardey Sub # 2  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mod

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>120</u>	<u>136</u>	<u>16</u>
<u>Clay</u>		<u>136</u>	<u>123</u>	<u>13</u>
<u>Sand</u>		<u>123</u>	<u>182</u>	<u>59</u>
<u>Coarse Sand</u>		<u>182</u>	<u>195</u>	<u>13</u>

8. WELL CONSTRUCTION 100'  
 Depth Drilled 195 Feet Depth Cased 115 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
5 9/16 Inches 120 Feet 195 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5 9/16</u>	<u>10</u>	<u>1.88</u>	<u>100</u>	<u>120</u>
<u>5 1/2</u>	<u>9</u>	<u>1.88</u>	<u>120</u>	<u>195</u>

Perforations:  
 Type perforation Jet Cut  
 Size perforation 3/16 x 5/8  
 From 180 feet to 193 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to N/A feet

9. WATER LEVEL  
 Static water level 40 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature C °F Quality Good

Date started 4/16/52 19\_\_\_\_  
 Date completed 4/20/52 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>45-50</u>	<u>5 1/2</u>	<u>4</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Juan Dominguez Contractor  
 Address PO Box 588 Contractor  
28. NV 89448  
 Nevada contractor's license number issued by the State Contractor's Board 0031841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1826  
 Signed Juan Dominguez  
 By driller performing actual drilling on site or contractor  
 Date 5/15/52