

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16431

1. OWNER John Ellis
 MAILING ADDRESS 2330 Paseo Del Prado Las Vegas NV 89102
 2. LOCATION S/W 1/4 N/E 1/4 Sec 21 T. 7 N R. 67 E Lincoln County
 PERMIT NO. 8-121-07 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--------------------|--------------|------|----|------------|
| TOP Soil- Boulders | | 0 | 27 | 27 |
| Clay | | 27 | 62 | 35 |
| gravel- boulders | X | 62 | 92 | 30 |
| Hard Rock | | 92 | 94 | 2 |

8. WELL CONSTRUCTION
 Depth Drilled 94 Feet Depth Cased 94 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 9.4 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>6 5/8</u> | <u>2</u> | <u>.188</u> | <u>0</u> | <u>94</u> |

Perforations:
 Type perforation Factory - torch cut
 Size perforation 1/8" x 3" - 1/8" x 6"
 From 64 feet to 94 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 94 feet

9. WATER LEVEL
 Static water level 57 feet below land surface
 Artesian flow 0 G.P.M. 0 P.S.I.
 Water temperature cold °F Quality good

Date started 9-25-97, 19____
 Date completed 9-27-97, 19____

7. WELL TEST DATA

| TEST METHOD: | TEST METHOD: <input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | |
|---------------|---|-------------------------------|--------------|
| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
| <u>Bailer</u> | <u>14</u> | <u>2</u> | <u>2</u> |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Davis Drilling Pumps Contractor
 Address PO. Box 54 Contractor
Hiko NV 89017
 Nevada contractor's license number issued by the State Contractor's Board 0028966
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
 Signed Mike Davis
 By driller performing actual drilling on site or contractor
 Date 9-29-97

CONTRACTOR
 RECEIVED
 DEC 5 1997
 LAS VEGAS

