

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35969

1. OWNER Jim Turner ADDRESS AT WELL LOCATION Lot 3  
 MAILING ADDRESS PO Box 291729  
Homerville NV

2. LOCATION NE 1/4 SW 1/4 Sec 23 T 33 N 57 E FKO County  
 PERMIT NO. 06-520-23-5 Parcel No. Cold Spring Ranch Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Loam</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Gravel</u>		<u>3</u>	<u>15</u>	<u>12</u>
<u>Hard PAN</u>		<u>15</u>	<u>60</u>	<u>45</u>
<u>SANDSTONE</u>		<u>60</u>	<u>112</u>	<u>52</u>
<u>ADBE SAND</u>	<u>X</u>	<u>112</u>	<u>150</u>	<u>38</u>

8. WELL CONSTRUCTION  
 Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 150 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/4</u>	<u>12.92</u>	<u>188</u>	<u>+2</u>	<u>152</u>

Perforations:  
 Type perforation Mill slots  
 Size perforation 3/16 + 3"  
 From 132 feet to 152 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 55

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 55 feet to 150 feet

9. WATER LEVEL  
 Static water level 6.0 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60.2 °F Quality \_\_\_\_\_

Date started 3-28 1997  
 Date completed 3-31 1997

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Apex</u>	<u>50</u>		<u>2.5</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fentig Drilling Co Contractor  
 Address PO Box 525 Contractor  
Elko NV 89803

Nevada contractor's license number issued by the State Contractor's Board 003190-1

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed Shane Fentig  
 By driller performing actual drilling on site or contractor

Date 4-14-97