


WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 69253
 Permit No. _____
 Basin. 082



NOTICE OF INTENT NO. 14014

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER ALTA GOLD CO. ADDRESS AT WELL LOCATION OLINGHOUSE MINE SITE
 MAILING ADDRESS 601 WHITNEY DR #10
HENDERSON, NV 89014

2. LOCATION SE $\frac{1}{4}$ NW $\frac{1}{4}$ Sec. 29 T. 21 S R. 23 E. WASHOE County
 PERMIT NO. M/O-1093 A N/A
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
GREY ROCK		0	80	80
BROKEN ROCK/CRACKS		80	120	40
NO RETURN		120	140	20
GREY ROCK		140	150	10
NO RETURN		150	180	30
BROKEN CLAY ROCK		180	195	15
BROWN GREY ROCK		200	210	10
GREY ROCK		210	225	15
CRACKS, NO RETURN		225	240	15
GREY ROCK		240	285	45
BROKEN ROCK		290	300	10
GREY ROCK		300	410	110
GREY BLACK ROCK		410	505	95
GREY BROKEN ROCK	X	505	570	65
GREY BLACK ROCK		570	645	75
GREY BROKEN ROCK		645	660	15
BROKEN UP GREY ROCK	X	660	695	35
POOR RETURN		695	735	40
GREY BROWN ROCK				
GREY BROWN ROCK		735	770	35

8. WELL CONSTRUCTION
 Depth Drilled 770 Feet Depth Cased 743 Feet

HOLE DIAMETER (BIT SIZE)
 From To
14-3/4 Inches 0 Feet 20 Feet
10 Inches 20 Feet 770 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10	28.04	.250	0	20
5	4.25	SCH 80	+2	403

Perforations:
 Type perforation SLOT
 Size perforation .020
 From 403 feet to 743 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 105 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 HOLE PLUG FROM 382 - 105
 Gravel Packed: Yes No
 From 745 feet to 382 feet

9. WATER LEVEL
 Static water level 280 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature _____ °F Quality _____

Date started 12-12-96, 19____
 Date completed 12-20-96, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING
Contractor
 Address 2286 WEST 1500 SOUTH
Contractor
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1995

Signed GUADALUPE JACOBO *Guadalupe Jacobo*
 By driller performing actual drilling on site or contractor
 Date 1-20-96