WHITE–DIVISION OF WATER RESOURCES
CANARY–CLIENT'S COPY
PINK–WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 6455
Permit No.
Basin 154

NOTICE OF INTENT NO. 32370

1. OWNER MARTIN HANSON
MAILING ADDRESS HCC2 BOX 166
EUREKA, NEVADA 89316
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ SE ¼ Sec. 30 T. 23 N R. 54 E. EUREKA County
PERMIT NO. 26437 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	4	4
BLACK SAND & GRAVEL		4	14	10
BLACK CLAY and SAND		14	171	157
SOME GRAVEL				
BLACK Sand Gravel	3	171	174	3
CLAY		174	180	6
BLACK SAND OR	7	180	187	7
CLAY		187	218	31
Black FINE SAND & CLAY		218	248	30
CLAY		248	315	67
SAND & GRAVEL	2	315	317	2
CLAY		317	328	11
SAND & GRAVEL	1	328	329	1
CLAY		329	356	27
SAND & GRAVEL	2	356	358	2
CLAY		358	360	2
SAND & GRAVEL	4	360	364	4
CLAY		364	374	10
SAND & GRAVEL	3	374	377	3
CLAY		377	383	6
SAND & GRAVEL	4	383	387	4
CLAY		387	407	20
SAND & GRAVEL	4	407	411	4
CLAY		411	417	6
SAND & GRAVEL	5	417	422	5
CLAY		422	426	3
SAND & GRAVEL	3	426	429	3
CLAY		429	438	9
SAND & GRAVEL		438	444	6
CLAY		444	452	

Date started 4-14, 19
Date completed 4-30-97, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1400	148'	8 hours

8. WELL CONSTRUCTION
Depth Drilled 452 Feet Depth Cased 452 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
28	TOP	452

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16"		1/4	TOP	272
12"		1/4	272	452

Perforations:
Type perforation ROSCO MOSS
Size perforation 1/8"
From 16" SF 151 feet to 191 feet
From 12" SF 312 feet to 352 feet
From 12" FF 352 feet to 372 feet
From 12" SF 372 feet to 412 feet
From 12" FF 412 feet to 432 feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From TOP feet to 452 feet

9. WATER LEVEL
Static water level 18' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WALTER L PLASKETT (Contractor)
Address BOX 10 (Contractor)
EUREKA NEV. 89316
Nevada contractor's license number issued by the State Contractor's Board 11882
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 635
Signed James E. Groth (By driller performing actual drilling on site or contractor)
Date 5-26-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

5-26-97

Sirs

the old well is being used as the Domestic well for the farmstead.

Please contact mr. Hanson for proper procedure to convert 16" casing to legal Domestic well.

thank you
James E. Groth
Box 255
Eureka nevada
89316.

Martin Hanson
HC 62 Box 166
Eureka nevada
89316