

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36569

1. OWNER Jim Oury ADDRESS AT WELL LOCATION Lat 24 Block F Humbolt Ranch Unit #1 Elko, NV
 MAILING ADDRESS P.O. Box 6096 Elko, NV
 2. LOCATION SW 1/4 NW 1/4 Sec 11 T 36 N S R 58 E Elk Co County
 PERMIT NO. 42 Issued by Water Resources Parcel No. 42 Subdivision Name Humbolt Acres Unit #1

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP soil		0	2	2
clay		0	69	67
clay sand		69	132	63
clay		132	153	21
clay gravel	X	153	173	20
clay		173	180	8

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 180 Feet
 Inches Feet Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>188</u>	<u>0</u>	<u>180</u>

Perforations:
 Type perforation Fee
 Size perforation
 From 150 feet to 170 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 180 feet

9. WATER LEVEL
 Static water level: 27 feet below land surface
 Artesian flow: G.P.M. P.S.I.
 Water temperature: °F Quality:

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Steve Well Service Contractor
 Address P.O. Box 10 Elko, NV Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0038169
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438
 Signed Sho Bennett
 By driller performing actual drilling on site or contractor
 Date 10-23-97

Date started 10-23 1997
 Date completed 10-23 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>207</u>	<u>30</u>	<u>2</u>