WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69368
Permit No.
Basin 82

NOTICE OF INTENT NO. 36041

1. OWNER Robert Cowles
MAILING ADDRESS 100 California Avenue
Reno, Nevada 89509

ADDRESS AT WELL LOCATION
2 miles NW of Wadsworth

2. LOCATION SE ¼ SE ¼ Sec 24 T 21 (N)S R 23 E Washoe County
PERMIT NO ~~46997~~, 61931, 62584 (Issued by Water Resources) --- (Parcel No.) --- (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock
Mining

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Mixed sand & gravel		0	85	85
Minor brown clay				
Sand, black cinder rock		85	128	43
Gray, brown, black rock, gravel		128	245	117
Sand and broken rock		245	368	123
Gray w/clay broken rock		368	398	30
Fractured gray rock		398	404	6
Black rock and clay		404	437	33
Broken rock and gravel		437	504	67

Date started October 27, 1997
Date completed November 10, 1997

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
700	33.2	5.5

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
14 3/4	0	505

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4	28.04	.250	+2	202
10 3/4	28.04	.250	492	502

Perforations:
Type perforation Wire Wrap Screen
Size perforation 50 Slot
From 202 feet to 492 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 505 feet

9. WATER LEVEL
Static water level 150.6 feet below land surface
Artesian flow --- G.P.M. ____ P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sargent Irrigation Company (Contractor)
Address 9955 North Virginia Street (Contractor)
Reno, Nevada 89506
Nevada contractor's license number issued by the State Contractor's Board 0021246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1593
Signed ____ (Driller performing actual drilling on site or contractor)
Date November 11, 1997

RECEIVED 1997 NOV 13 AM 10:09 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627