WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 09273
Permit No.
Basin 70

NOTICE OF INTENT NO. 35040

1. OWNER Kim Peterson
MAILING ADDRESS P.O. Box 1265
Winnemucca, NV 89446

ADDRESS AT WELL LOCATION Lot 35
4445 Maxine Winnemucca

2. LOCATION 1/4 W1/2 1/4 Sec. 17 T 36N N/S R 38 E Humboldt County
PERMIT NO. Issued by Water Resources 10-207-03 Parcel No. Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay w/cobbles		0	115	115
Clay		115	170	55
Clay w/small sand & gravel		170	230	60
Clay		230	255	25
Clay w/sand & gravel layers		255	300	45

Date started 9/22/97, 19__
Date completed 9/24/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		2 hrs.

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 285 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 7/8	Inches	0	Feet	230	Feet
6 1/8	Inches	230	Feet	300	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	230
5 9/16		.188	185	285

Perforations:
Type perforation Mill slot
Size perforation 1/8 x 3
From 190 feet to 230 feet
From 245 feet to 285 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 230 feet

9. WATER LEVEL
Static water level 126 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc.
Contractor
Address 4675 W. Winnemucca Blvd
Contractor
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562

Signed Jerrit Tompk
By driller performing actual drilling on-site or contractor

Date 10-6-97