WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 109276
Permit No.
Basin 71

NOTICE OF INTENT NO. 38417

1. OWNER Rich Brown
MAILING ADDRESS 3565 Brown Lane
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION
4690 Cowboy

2. LOCATION SW 1/4 SE 1/4 Sec. 7 T 35N N/S R 38 E Humboldt County
PERMIT NO. _____ Issued by Water Resources | 10-485-3 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	5	5
Gravel & cobbles		5	78	73
Clay w/cobbles		78	145	67
Fractured rock w/clay		145	177	32
Fractured rock	x	177	225	48

Date started 10/4/97, 19__
Date completed 10/5/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1.5 hrs.

8. WELL CONSTRUCTION
Depth Drilled 225 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 7/8	Inches	0 Feet	225 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	220

Perforations:
Type perforation Mill slot
Size perforation 1/8 x 3
From 180 feet to 220 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 225 feet

9. WATER LEVEL
Static water level 161 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc.
Contractor
Address 4675 W. Winnemucca Blvd
Contractor
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562

Signed [signature]
By driller performing actual drilling on-site or contractor

Date 10-9-97