WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69285
Permit No. 43
Basin

NOTICE OF INTENT NO. 38558

1. OWNER JIM CURRIVAN
MAILING ADDRESS STARR VALLEY RT BOX 97
DEETH, NV 89823

ADDRESS AT WELL LOCATION
STARR VALLEY, NEVADA

2. LOCATION NW 1/4 SE 1/4 Sec. 4 T 36N N/S R 60E E ELKO County
PERMIT NO. _____ Issued by Water Resources | 07-550-41-1 Parcel No. | TRACT OF LAND Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	4	4
SAND, GRAVEL & BOULDERS		4	30	26
BROWN CLAY & GRAVEL		30	90	60
QUARTZ & SAND	X	90	160	70

Date started 10/9/97, 19__
Date completed 10/10/97, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		3

8. WELL CONSTRUCTION

Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	160

Perforations:
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 140 feet to 160 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [ ] Pumped [X] Poured

Seal Type:
[X] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 160 feet

9. WATER LEVEL

Static water level 75 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc.
Contractor

Address P.O. Box 850
Contractor

Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689

Signed [signature]
By driller performing actual drilling on-site or contractor

Date 10-13-97