WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69294
Permit No.
Basin 63

NOTICE OF INTENT No. [redacted]

1. OWNER MIDAS JOINT VENTURE
MAILING ADDRESS 6151 LAKESIDE DR. SUITE 2100
RENO, NV 89511

ADDRESS AT WELL LOCATION
KEN SNYDER MINE NEAR MIDAS, NEVADA

2. LOCATION NE / 1/4 NE 1/4 Sec. 27 T 39N N/S R 46E E ELKO County
PERMIT NO. MW-1134 (Issued by Water Resources) | MW-1 (Parcel No.) | TRACT OF LAND (Subdivision Name)

**3. WORK PERFORMED**
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other _____

**4. PROPOSED USE**
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

**5. WELL TYPE**
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other _____

**6. LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Drilled holes around monument | | | | |
| Pulled monument & PVC casing | | | | |
| Drilled 0-78 to clean out hole | | | | |
| Pumped abandonite from bottom to surface | | | | |
| 240 gallons of water with 6-50 lb bags | | | | |
| of abandonite | | | | |
| Pumped neat cement from 50' to surface | | | | |
| 10-94lb bags of cement | | | | |

Date started 9/16/97 , 19__
Date completed 9/16/97 , 19__

**7. WELL TEST DATA**
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| | | | |
| | | | |
| N/A | | | |
| | | | |
| | | | |
| | | | |

**8. WELL CONSTRUCTION**
Depth Drilled 78 Feet Depth Cased N/A Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 6.5 | Inches | 0 | Feet | 78 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| N/A | | | | |
| | | | | |
| | | | | |

Perforations:
Type perforation N/A
Size perforation
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From _____ feet to _____ feet

**9. WATER LEVEL**
Static water level 34 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

**10. DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654

Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 10-2-97