

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 69295  
 Permit No. \_\_\_\_\_  
 Basin 101  
 NOTICE OF INTENT NO. 36750

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Skip Hitchcock ADDRESS AT WELL LOCATION 5083 Reno Hwy, Fallon, NV 89406  
 MAILING ADDRESS 4925 Reno Hwy Fallon, NV 89406

2. LOCATION SE 1/4 NE 1/4 Sec. 29 T 19N N/S R 28E E Churchill County  
 PERMIT NO. 57016 Issued by Water Resources Parcel No. 008-492-08 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Municipal  Irrigation  Test  
 Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	17	17
Clay		17	21	4
Sand		21	37	16
Coarse Brown sand		37	48	11
Sandy Clay		48	53	5
Green Clay		53	57	4
Green Sand		57	68	11
Gray Sand		68	76	8
Gray Clay		76	78	2
Gray Sand		78	84	6
Brown Sand		84	98	14
Coarse Sand		98	110	12
Brown Clay		110	117	7
Gray & Brown Clay		117	128	11
Gray Sand		128	135	7
Gray & Brown Clay		135	152	17
Red Brown Sand	X	152	164	12

8. WELL CONSTRUCTION  
 Depth Drilled 164 Feet Depth Cased 164 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 164 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	164

Perforations:  
 Type perforation Mill Cut  
 Size perforation 1/8  
 From 161 feet to 164 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 100  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 100 feet to 164 feet

9. WATER LEVEL  
 Static water level 21.6 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Parsons Drilling, Inc. Contractor  
 Address P.O. Box 1265 Contractor  
Fallon, NV 89407-1265  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1696  
 Signed Wendy Parsons  
 By driller performing actual drilling on-site or contractor  
 Date 9-12-97

Date started 8/12/97, 19\_\_\_\_  
 Date completed 8/13/97, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>	<u>1 hr.</u>	