

OFFICE USE ONLY
 Log No. 19304
 Permit No. _____
 Basin 176

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33253

1. OWNER Mike Cecchi ADDRESS AT WELL LOCATION Lot #6 Block C Unit # 1
 MAILING ADDRESS 10890 O'Sage
Reno, NV 89506

2. LOCATION NE 1/4 SE 1/4 Sec 9 T. 28 N/S R. 58 east Elko County
 PERMIT NO. 07-03A-15-6 Parcel No. _____ Subdivision Name Ruby Valley Estates
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
D.G. Brown		0	10	10
Brown fine sand		10	20	10
Brown clay with Multi colored Gravel		20	65	45
Multi colored Gravel	X	65	135	70
Brown sticky clay		135	160	25
T.D. 160'				

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.92	.188	+1 1/2	160

Perforations:
 Type perforation Factory Sawn
 Size perforation 3/32 x 3
 From 100 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 160 feet to 50 feet

9. WATER LEVEL
 Static water level 40' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality _____

Date started May 8 19 97
 Date completed May 8 19 97

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		2hrs.

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. Pump & Well Service, Inc. Contractor
 Address 1800 1/2 Frazer Ave. Contractor
Sparks NV 89431
 Nevada contractor's license number issued by the State Contractor's Board 35387-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date May 15, 1997