WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69306
Permit No.
Basin 176

NOTICE OF INTENT NO. 33254

1. OWNER Leroy Perks Sr.
MAILING ADDRESS P.O. Box 18074
Reno, NV 89511

ADDRESS AT WELL LOCATION Lot #8 Block C Unit#1

2. LOCATION NE ¼ SE ¼ Sec. 9 T. 28 N/S R. 58 E.ast Elko County
PERMIT NO. (Issued by Water Resources) 07-034-17-2 (Parcel No.) Ruby Valley Estates (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Brown D.G. | | 0 | 10 | 10 |
| Brown fine sand | | 10 | 20 | 10 |
| Multi colored large Gravel | | 20 | 30 | 10 |
| Brown clay with multi colored gravel | | 30 | 60 | 30 |
| Brown clay with multi colored grav. | X | 60 | 95 | 35 |
| brown clay | | 95 | 120 | 25 |
| T.D. 120' | | | | |

Date started May 7, 1997
Date completed May 7, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20+ | | 2hrs. |

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 5/8 Inches | 0 Feet | 120 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13.92 | .188 | +1½ | 120 |

Perforations:
Type perforation Factory Sawed
Size perforation 3/32 x 3
From 80 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 120 feet to 50 feet

9. WATER LEVEL
Static water level 35 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A.S.A.P. Pump & Well Service, Inc. (Contractor)
Address 1800 ½ Frazer Ave. (Contractor)
Sparks, NV 89431
Nevada contractor's license number issued by the State Contractor's Board 35387-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066
Signed Larry Wilet (By driller performing actual drilling on site or contractor)
Date May 12, 1997

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627