

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 69308  
 Permit No. \_\_\_\_\_  
 Basin. 103

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35391  
369 Comstock

1. OWNER Gary Laack ADDRESS AT WELL LOCATION 369 Comstock  
 MAILING ADDRESS 369 Comstock Dayton, NV 89403  
 DAYTON, NV 89403

2. LOCATION NW 1/4 SE 1/4 Sec 4 T 16 N 22 East Lyon County  
 PERMIT NO. 19-131-11 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mild

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand w/ Multi Colored Gravel		0	25	25
Gray Sand w/ Multi Colored Gravel		25	65	40
Multi Colored Fine Sand		65	100	35
Multi Colored Course Sand		100	115	15
Multi Colored Gravel	X	115	140	25
Multi Colored Gravel w/ Brown Clay		140	142	2
Multi Colored Gravel & Fine Sand		142	150	8
Multi Colored Gravel & Brown Clay		150	153	3
Brown Clay & Multi Colored Course Sand		153	160	7
T.D. 160				

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.92	188	+ 1 1/2	160

Perforations:  
 Type perforation Factory Sawn  
 Size perforation 3/32 X 3  
 From 1.00 feet to 1.20 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 7.2  
 Placement Method:  Pumped  
 Poured

Gravel Packed:  Yes  No  
 From 1.60 feet to 7.2 feet

9. WATER LEVEL  
 Static water level: 20 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality \_\_\_\_\_

Date started November 4, 1997  
 Date completed November 7, 1997

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

Draw Down (Feet Below Static) \_\_\_\_\_ Time (Hours) 2 hours

RECEIVED  
 07 NOV 11 AM 11:05  
 STATE ENGINEERS

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service, Inc.  
P.O. Box 60130 Contractor  
 Address \_\_\_\_\_ Contractor  
Reno, NV 89506

Nevada contractor's license number 35387-A  
 issued by the State Contractor's Board.

Nevada driller's license number issued by the  
 Division of Water Resources, the on-site driller: 2066

Signed Gary Laack  
 By driller performing actual drilling on site or contractor  
 Date November 9, 1997