

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35388

1. OWNER Don Stromquist ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 2291 Empire Rd. _____
Reno, NV 89511 _____
2. LOCATION SE 1/4 NE 1/4 Sec 32 T 18 Q/S R 21 East Storey County
PERMIT NO. 03-045-56 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Green & gray clay				
Mullti colored Voc Rock		197	205	8
Green & gray Clay		205	215	10
Gray clay		215	240	25
Gray clay black vocn Rock		240	285	45
Black volcanic rock		285	300	15
Black & gray clay stone		300	335	35
Gray green clay stone		335	340	5
Black volc rock and white clay		340	375	35
Black volc & green clay		375	385	10
Multi color vol rock		385	425	40
T.D. 425'				
Fish out liner 97' to 197'				

8. WELL CONSTRUCTION
Depth Drilled 425 Feet Depth Cased 425 Feet
HOLE DIAMETER (BIT SIZE)
From 6 1/8 Inches To 197 Feet 425 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"	6.56	.188	85	425

Perforations:
Type perforation Factory Sawn
Size perforation 3/32 x 3
From 385 feet to 425 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal In Place Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 200 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service, Inc. Contractor
Address P.O. Box 60130 Contractor
Reno, NV 89506
Nevada contractor's license number 35387-A
issued by the State Contractor's Board
Nevada driller's license number issued by the 2066
Division of Water Resources, the on-site driller
Signed Sam Welch
By driller performing actual drilling on site or contractor
Date October 17, 1997

Date started October 8, 1997
Date completed October 11, 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>		<u>3hrs.</u>