


Log No. 09322
Permit No. 49
Basin _____



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36573

1. OWNER Roy Elmer ADDRESS AT WELL LOCATION Cherry Lane
MAILING ADDRESS P.O. Box 5644 Adobe Heights Elko NV
Elko NV 89802

2. LOCATION NE 1/4 NE 1/4 Sec 12 T 35 N R 51 E Elko County
PERMIT NO. 005-526-023 Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP Soil		0	2	2
Cobbles		2	6	4
sand stone		6	12	6
gravel sand		12	110	98
sand stone		110	251	141
sand stone clay	X	251	275	24
Sandstone		275	298	23
clay sandstone	X	298	312	14
clay		312	320	8

8. WELL CONSTRUCTION
Depth Drilled 320 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)
From _____ To _____
10 Inches 0 Feet 320 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>188</u>	<u>0</u>	<u>320</u>

Perforations:
Type perforation Free slot
Size perforation 1/8 x 6
From 285 feet to 305 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 320 feet

9. WATER LEVEL
Static water level 172 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Steve Well Service Contractor
Address P.O. Box 10 Elko NV Contractor
Nevada contractor's license number issued by the State Contractor's Board 0038169
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438
Signed Shane Bennett
By driller performing actual drilling on site or contractor
Date NOV-30-97

Date started NOV-30, 1997
Date completed DEC-2, 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>113</u>	<u>2</u>

RECEIVED
07 DEC 10 AM 10:43
STATE ENGINEERS OFFICE