

OFFICE USE ONLY  
 Log No. 69323  
 Permit No. 48  
 Basin.....  
 NOTICE OF INTENT NO. 36612

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER SONNIE DAVIS ADDRESS AT WELL LOCATION Lot 8 - RUBY MOUNTAIN ESTATES  
 MAILING ADDRESS 866 Spring Valley Elko NV 89801  
 2. LOCATION SW 1/4 SE 1/4 Sec. 23 T. 33 N. R. 56 E. Elko County  
 PERMIT NO. 079-002-008 Parcel No. Ruby MT ESTATES Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other M.D.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Loam</u>		<u>0</u>	<u>1</u>	<u>1</u>
<u>Gravel</u>		<u>1</u>	<u>6</u>	<u>5</u>
<u>CLAY</u>		<u>6</u>	<u>42</u>	<u>36</u>
<u>SANDSTONE</u>		<u>42</u>	<u>84</u>	<u>42</u>
<u>CLAY</u>		<u>84</u>	<u>97</u>	<u>15</u>
<u>SANDSTONE</u>		<u>97</u>	<u>103</u>	<u>6</u>
		<u>103</u>	<u>120</u>	<u>17</u>

8. WELL CONSTRUCTION  
 Depth Drilled 120 Feet Depth Cased 120 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 120 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.92</u>	<u>1.88</u>	<u>71.5</u>	<u>120</u>

Perforations:  
 Type perforation mill slot  
 Size perforation 3/16 x 3"  
 From 120 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 54  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 54 feet to 120 feet

9. WATER LEVEL  
 Static water level 40 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality \_\_\_\_\_

Date started 9-8, 1997  
 Date completed 9-9, 1997

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Apex</u>	<u>55</u>	<u>NA</u>	<u>6.00</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Fertig Drilling Co Contractor  
 Address PO Box 525 Contractor  
Elko NV 89803  
 Nevada contractor's license number 0031904  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1584  
 Signed Shouk Jureid  
 By driller performing actual drilling on site or contractor  
 Date 9-12-97