

OFFICE USE ONLY
 Log No. 69324
 Permit No. _____
 Basin. 49

36613

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36613

1. OWNER JAY Rolasen ADDRESS AT WELL LOCATION KAYENTA + McHenry
 MAILING ADDRESS P.O. Box 311
EIKO NV 89802

2. LOCATION SE 1/4 NW 1/4 Sec 36 T 36 N/S R 56 E County EIKO
 PERMIT NO. 06-006-334-0234 Parcel No. Ryndon Subdivision Name McHenry

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM		0	2	2
SANDSTONE		2	98	96
SOFT SAND & Gravel	X	98	105	7
CLAY		105	120	15
SANDSTONE		120	134	14
LOOSE SANDSTONE	X	134	160	26

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 3/8 Inches To 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.92</u>	<u>1.88</u>	<u>72</u>	<u>160</u>

Perforations:
 Type perforation Mill slot
 Size perforation 3/16 x 3"
 From 140 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 5.5

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 55 feet to 160 feet

9. WATER LEVEL
 Static water level 100 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality _____

Date started 9-3, 1997
 Date completed 9-7, 1997

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>APCER</u>	<u>90</u>		<u>2.00</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name FERTIG DRILLING CO Contractor
 Address P.O. Box 525 Contractor
EIKO NV 89803

Nevada contractor's license number issued by the State Contractor's Board 0031904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed Shouk Fertil
 By driller performing actual drilling on site or contractor

Date 9-12-97