


OFFICE USE ONLY
 Log No. 69325
 Permit No. 79
 Basin 79



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 3667

1. OWNER Arvid Graig ADDRESS AT WELL LOCATION Lot 5 Blk 8
 MAILING ADDRESS 160-10 Kittredge Cyn Elko NV 89801
 2. LOCATION NE 1/4 NE 1/4 Sec. 33 T. 35 N. 55 E. Elko County
 PERMIT NO. 037-008-005 MUR # 5 Subdivision Name Kittredge Cyn
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Rocks</u>		<u>0</u>	<u>6</u>	<u>6</u>
<u>White Sufish SANDSTONE</u>		<u>6</u>	<u>131</u>	<u>125</u>
<u>Cemented SANDSTONE</u>		<u>131</u>	<u>174</u>	<u>43</u>
<u>White SANDSTONE</u>		<u>174</u>	<u>198</u>	<u>24</u>
<u>SAND mix Gravel</u>	<u>X</u>	<u>198</u>	<u>226</u>	<u>28</u>

8. WELL CONSTRUCTION
 Depth Drilled 226 Feet Depth Cased 226 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 226 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/4</u>	<u>12.92</u>	<u>1.88</u>	<u>12</u>	<u>226</u>

Perforations:
 Type perforation Mill slot
 Size perforation 3/16 x 3"
 From 200 feet to 220 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 55
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 55 feet to 226 feet

9. WATER LEVEL
 Static water level 150 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fertig Drilling Co Contractor
 Address P.O. Box 525 Contractor
Elko NV 89803
 Nevada contractor's license number issued by the State Contractor's Board 0031904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
 Signed Shaul Fertig
 By driller performing actual drilling on site or contractor
 Date 9-8-97

Date started 9-1, 1997
 Date completed 9-2, 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Approx</u>	<u>40</u>		<u>2.5</u>

RECEIVED
 97 SEP 16 AM 11:09
 STATE ENGINEERING OFFICE