WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69329
Permit No.
Basin 89

NOTICE OF INTENT NO. 38014

1. OWNER Rich Mason
MAILING ADDRESS 5360 Franktown Rd.
Carson City, NV 89704

ADDRESS AT WELL LOCATION
5360 Franktown Rd., Carson City NV

2. LOCATION SW 1/4 SW 1/4 Sec. 10 T 16N N/S R 19E E Washoe County
PERMIT NO. Wa Co#6005 (Issued by Water Resources) 55-060-20 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
We tagged bottom of the well at				
285'. We drilled to 610'.				
Fill		285	290	5
White Frac. Franite w/clay		290	450	160
Black Granite, less Frac		450	610	160

Date started 11/12/97, 19__
Date completed 11/20/97, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
33	174	6 hours

8. WELL CONSTRUCTION
Depth Drilled 610 Feet Depth Cased 610 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 1/8 Inches		285 Feet	610 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"	10.79	.188	30	610

Perforations:
Type perforation Factory
Size perforation 3/32" x 3" single row
From 330 feet to 350 feet
From 370 feet to 390 feet
From 410 feet to 430 feet
From 470 feet to 490 feet
From 530 feet to 550 feet
570 610

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 0 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
RENO, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719

Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 12-1-97