WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69342
Permit No. 49
Basin

NOTICE OF INTENT NO. 38577

1. OWNER ADOBE HTS C/O CONN DAVIS
MAILING ADDRESS P.O. BOX 7316
INCLINE VILLIAGE, NV 89452

ADDRESS AT WELL LOCATION
SO. SIDE OF PUEBLO DR. IN ADOBE HTS. ELKO, NV

2. LOCATION NW 1/4 SE 1/4 Sec. 1 T 34N N/S R 54E E ELKO County
PERMIT NO. _____ (Issued by Water Resources) | 5-51D-028 (Parcel No.) | SPECIAL LANDS (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	6	6
SILTSTONE		6	140	134
BLUE SILTSTONE		140	300	160
BLUE CLAY		300	580	280
See next line	X	580	640	60
BLUE SILTSTONE & SMALL GRAVEL				

Date started 10/15/97, 19__
Date completed 10/17/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		5

8. WELL CONSTRUCTION
Depth Drilled 640 Feet Depth Cased 640 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8	Inches	0 Feet	640 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	640

Perforations:
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 620 feet to 640 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 640 feet

9. WATER LEVEL
Static water level 563 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689

Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 11-11-97