WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69343
Permit No.
Basin 37

NOTICE OF INTENT NO. 38571

1. OWNER COLIN PERRY
MAILING ADDRESS P.O. BOX 206
MOUNTAIN CITY, NV 89831

ADDRESS AT WELL LOCATION
SR 225 AT MILE MARKER 106 - NEAR MT. CITY

2. LOCATION NW 1/4 SW 1/4 Sec. 19 T 45N N/S R 54E E ELKO County
PERMIT NO. (Issued by Water Resources) 5-620-003 (Parcel No.) TRACT OF LAND (Subdivision Name)

**3. WORK PERFORMED**
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

**4. PROPOSED USE**
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

**5. WELL TYPE**
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

**6. LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| TOPSOIL | | 0 | 2 | 2 |
| BROWN CLAY & GRAVEL | | 2 | 20 | 18 |
| GRAVEL | | 20 | 25 | 5 |
| CLAY & GRAVEL | | 25 | 60 | 35 |
| VOLCANIC | X | 60 | 140 | 80 |

Date started 10/24/97, 19__
Date completed 10/28/97, 19__

**7. WELL TEST DATA**
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20 | | 5 |

**8. WELL CONSTRUCTION**
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 5/8 | Inches | 0 Feet | 140 Feet |
| | Inches | Feet | Feet |
| | Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13 | .188 | +1 | 140 |
| | | | | |

Perforations:
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 140 feet

**9. WATER LEVEL**
Static water level 15 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

**10. DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689

Signed David W. Hersh by [illegible]
By driller performing actual drilling on-site or contractor

Date 10-31-97