

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15892

1. OWNER John Russell ADDRESS AT WELL LOCATION 9700 Betty Lane
 MAILING ADDRESS 9700 Betty Lane W.M.C.A., NV
 2. LOCATION NE 1/4 SW 1/4 Sec. 30 T. 35 S. R. 38 E Humboldt County
 PERMIT NO. 10-942-08 Parcel No. ZRS Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND/gravel - 95%		0	40	40'
Clay 5%				
SAND/gravel - 70%		40	60	20'
Clay 30%				
Clay/SAND/gravel		60	110	50'
Clay/gravel		110	140	30'
gravel	X	140	170	30'
gravel - 75%	X	170	200	30'
SAND - 25%				
gravel - 95%	X	200	230	30'
SAND - 5%				

8. WELL CONSTRUCTION
 Depth Drilled 230 Feet Depth Cased 230 Feet
 HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 230 Feet To 230 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>	<u>12</u>	<u>188</u>	<u>0</u>	<u>230</u>

Perforations:
 Type perforation Factory Cuts
 Size perforation 3/32
 From 200 feet to 230 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 230 feet

9. WATER LEVEL
 Static water level 150 feet below land surface
 Artesian flow NO G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality Good

Date started 5-25 1995
 Date completed 5-29 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>39</u>	<u>N/A</u>	<u>3 hr.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name FRED ANDERSON Contractor
 Address 10760 Grass Vly Contractor
WINNEMUCCA, NV
 Nevada contractor's license number issued by the State Contractor's Board 0012467
 Nevada driller's license number issued by the Division of Water Resources 1375
 Signed _____
 By driller performing actual drilling on site or contractor
 Date 6-29-95