WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69405
Permit No.
Basin 161

NOTICE OF INTENT NO. 16264

1. OWNER NEVADA STATE LANDS DIVISION
MAILING ADDRESS
ADDRESS AT WELL LOCATION INDIAN SPRINGS PRISON

2. LOCATION NW ¼ NW ¼ Sec. 33 T. 16 N/S 57 E. CLARK County
PERMIT NO. W-2078 (Issued by Water Resources) 560-360-016 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
COBBLES & GRAVEL		0	5	5
SANDY CLAY & GRAVEL		5	40	35
SAND & GRAVEL		40	50	10
SANDY CLAY & GRAVEL		50	135	85
COARSE GRAVEL & CLAY		135	150	15
SANDY CLAY & GRAVEL		150	185	35
SAND & GRAVEL		185	195	10
CEMENTED SAND & GRAVEL		195	250	55
SANDY CLAY & GRAVEL		250	275	25
CEMENTED SAND & GRAVEL				
	X	275	390	115
SANDY CLAY		390	400	10
SAND & GRAVEL	X	400	485	85
SANDY CLAY & GRAVEL	X	485	500	15
SAND & GRAVEL	X	500	530	30
SANDY CLAY & GRAVEL	X	530	575	45
SAND & GRAVEL	X	575	600	25

DEC 15 1997

Date started 10/10, 19 97
Date completed 12/4, 19 97

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
270	115	24

8. WELL CONSTRUCTION
Depth Drilled 600 Feet Depth Cased 600 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
18 Inches		0 Feet	600 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12 3/4	33.38	.250	+2	600

Perforations:
Type perforation FACTORY SAW
Size perforation 1/8 X 3" 12 ROWS
From 360 feet to 560 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 600 feet

9. WATER LEVEL
Static water level 238 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WATER WELL SERVICES (Contractor)
Address 6475 GARY AVE. (Contractor)
LAS VEGAS, NV 89139
Nevada contractor's license number issued by the State Contractor's Board 0022311B
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on site or contractor)
Date 12/4/97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627