

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

Log No. 107415  
 Permit No. 102  
 Basin 102

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25033

1. OWNER Dan Barber ADDRESS AT WELL LOCATION 2050 Fir Street, Silver Springs, NV, 89429  
 MAILING ADDRESS P.O. Box 242  
Yerington, NV 89447

2. LOCATION SE 1/4 SE 1/4 Sec 35 T. 18 N/S R. 24 E Lyon County  
 PERMIT NO. N/A 15-211-45  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden, Clay, Sand		0	4	
Brown Clay, Sand		4	24	
Grey Clay, Sand		24	58	
Yellow Clay, Sand		58	110	
Fractured Shist		110	123	
Shist		123	158	
Fractured Shist		158	160	
Shist		160	192	
Fractured Shist		192	194	
Shist		194	211	
Fractured Shist		211	215	
Shist		215	240	

8. WELL CONSTRUCTION  
 Depth Drilled 240 Feet Depth Cased 240 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 3/4 Inches 0 Feet 50 Feet  
8 5/8 Inches 50 Feet 240 Feet  
 ..Inches.....Feet.....Feet  
*Pen telcon w/Diamond 10-17-97*

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	0	240

Perforations:  
 Type perforation Factory Slotted  
 Size perforation.....  
 From 160 feet to 180 feet  
 From 200 feet to 220 feet  
 From.....feet to.....feet  
 From.....feet to.....feet  
 From.....feet to.....feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 240 feet

9. WATER LEVEL  
 Static water level 96 feet below land surface  
 Artesian flow N/A G.P.M. P.S.I.  
 Water temperature COOL °F Quality.....

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Diamond Well Drilling Co. Contractor  
 Address 1660 Old Airport Road Contractor  
Auburn, CA 95602  
 Nevada contractor's license number issued by the State Contractor's Board 34841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1983  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 9/27/96

Date started 9/16/96 19.....  
 Date completed 9/17/96 19.....

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>3</u>		<u>4</u>