

OFFICE USE ONLY
 Log No. 69419
 Permit No. _____
 Basin 099
 NOTICE OF INTENT NO. 33606

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER N & B DAVIDSON ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2545 Westview Blvd Sparks NV 89432 16750 Red Rock Rd Reno NV
 2. LOCATION SW 1/4 SE 1/4 Sec 4 T 23 S R 18 E WASHOE County
 PERMIT NO. 7802203 Parcel No. _____ Subdivision Name RANCHO HAVEN

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ALUMINUM		0	20	20
DECOMPOSED GRANODIORITE		20	60	40
HARD DG		60	65	5
LT BROWN CLAY		65	80	15
HARD RUBBLEY DG		80	120	40
HARD DG	X	120	180	60
LT BWN CLAY		180	220	40
MORE DG	X	220	300	80

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 55
12 1/4 Inches 0 Feet 55 Feet
10 Inches 55 Feet 300 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13</u>	<u>.188</u>	<u>+2</u>	<u>300</u>

 Perforations:
 Type perforation SAUCWT
 Size perforation 3x 3/32
 From _____ feet to _____ feet
 From 220 feet to 300 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 55 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 55 feet to 300 feet

Date started 4/14 1997
 Date completed 4/19 1997

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>		<u>3</u>

9. WATER LEVEL
 Static water level 140 feet below land surface
 Artesian flow No G.P.M. _____ P.S.I. _____
 Water temperature Cool °F Quality ?
 10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA DRILLING, INC Contractor
 Address 75 LEWERS CREEK RD Contractor
WASHOE VALLEY, NV 89704
 Nevada contractor's license number 13697A
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1470
 Signed Joe Leisler
 By driller performing actual drilling on site or contractor
 Date 4/30/97