

44449

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 69422  
Permit No. \_\_\_\_\_  
Basin 042

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36292  
Block B lot 4

1. OWNER Tom Pratt ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS 100 W. Grove #125  
Reno, Nv 89509  
2. LOCATION NE 1/4 NE 1/4 Sec 3 T. 36 N. R. 58 E. Elko County  
PERMIT NO. 19-002-11-2 Parcel No. \_\_\_\_\_ Subdivision Name Humboldt Acres Unit 2  
Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	5	5
Gravel, Sand		5	20	15
Gravel, Clay, Sand		20	30	10
Sand, Gravel		30	55	25
Clay, Gravel, Sand		55	100	5
Sand, Gravel		100	90	30
Gravel, Sand, Clay		90	95	5
Gravel, Sand		95	105	10
Sand		105	120	15
Gravel, Clay, Sand		120	125	5
Clay		125	130	5
Gravel, Sand		130	135	5
Clay, Sand, Gravel		135	145	10
Sand, Gravel	X	145	165	20
Clay, Sand		165	170	5
Clay, Gravel, Sand		170	208	38

8. WELL CONSTRUCTION  
Depth Drilled 208 Feet Depth Cased 208 Feet  
HOLE DIAMETER (BIT SIZE)  
From 10 5/8 Inches To 0 Feet 208 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>		<u>.188</u>	<u>0</u>	<u>208</u>

Perforations:  
Type perforation mill slot  
Size perforation FACTORY  
From 162 feet to 202 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 50 feet to 208 feet

9. WATER LEVEL  
Static water level 117 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cold °F Quality poor

Date started 5-3 1997  
Date completed 5-5 1997

7. WELL TEST DATA

TEST METHOD: <input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name AAA Drilling and Pump/STACO Contractor  
Address 3359 East Chance Rd Contractor  
Elko, Nv 89801  
Nevada contractor's license number issued by the State Contractor's Board 0038169  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2053  
Signed \_\_\_\_\_  
By driller performing actual drilling on site or contractor  
Date 5-5-97