

2-009

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 69423  
Permit No. \_\_\_\_\_  
Basin 042

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36291  
ADDRESS AT WELL LOCATION Block A Lot 4

1. OWNER Tom Pratt  
MAILING ADDRESS 100 W. Grove St #125  
Reno, NV. 89509

ADDRESS AT WELL LOCATION Block A Lot 4

2. LOCATION NW 1/4 NW 1/4 Sec. 11 T. 36 N. R. 58 E. Elko County  
PERMIT NO. 18-001-04-9 Parcel No. \_\_\_\_\_ Subdivision Name Humboldt Acres UNIT #1

County Elko  
Subdivision Name Humboldt Acres UNIT #1

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	10	10
GRAVEL, SAND		10	20	10
GRAVEL, CLAY		20	30	10
CLAY, SAND		30	40	10
Black sand, Clay		40	55	15
Clay, gravel		55	70	15
GRAVEL, CLAY	X	70	83	13
CLAY		83	95	10
Clay, gravel	X	95	110	15
GRAVEL SAND, CLAY		110	120	10
Black CLAY, SAND		120	160	40

8. WELL CONSTRUCTION  
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)  
From To  
10 5/8 Inches 0 Feet 160 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>		<u>e 188</u>	<u>-1</u>	<u>160</u>

Perforations:  
Type perforation Mill Slot  
Size perforation FACTORY  
From 120 feet to 140 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50 FT  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 50 feet to 160 feet

9. WATER LEVEL  
Static water level 35 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature COld °F Quality POOR

Date started 4-29 1997  
Date completed 5-1 1997

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name AAA Drilling and Pump/Starco Contractor  
Address 3359 Last Chance Rd Contractor  
Elko, Nevada 89801  
Nevada contractor's license number issued by the State Contractor's Board 0038169  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2053  
Signed \_\_\_\_\_  
By driller performing actual drilling on site or contractor  
Date 5-1-97