

OFFICE USE ONLY
 Log No. 69424
 Permit No. _____
 Basin 042

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36290

1. OWNER Tom Pratt ADDRESS AT WELL LOCATION Block N Lot 1
 MAILING ADDRESS 100 W. Grove # 125
RENO, NV 89509
 2. LOCATION NE 1/4 NE 1/4 Sec. 11 T. 36 N. R. 58 E. E. EIKO County
 PERMIT NO. 18-014-01-9 Humboldt Acre - Unit #1
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	10	10
Gravel		10	30	20
Gravel, Clay		30	55	25
Clay, Sand, Gravel	X	55	90	35
Sand		90	95	5
Clay, sand		95	220	125
Clay, Claystone, Sand		220	230	10
Clay, Sand	X	230	300	70

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 300 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>		<u>.188</u>	<u>0</u>	<u>300</u>

Perforations:
 Type perforation Mill Slot
 Size perforation Factory
 From 240 feet to 280 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Ft Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 100 feet to 300 feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow Flowing less than 1000 P.M. P.S.I.
 Water temperature Cold °F Quality Poor

Date started 4-22 1997
 Date completed 4-27 1997

7. WELL TEST DATA

TEST METHOD: <input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name AAA Drilling and Pump/Service Contractor
 Address 3359 Last Chance Road Contractor
EIKO, Nevada 89801
 Nevada contractor's license number issued by the State Contractor's Board 0038169
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2053
 Signed _____
 By driller performing actual drilling on site or contractor
 Date 4-27-97