

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36293

1. OWNER Tom Pratt ADDRESS AT WELL LOCATION Block J Lot 4  
 MAILING ADDRESS 100 W. Grove #125  
Heno, NV. 89509

2. LOCATION NW 1/4 SE 1/4 Sec. 3 T. 36 N. R. 58 E. Elko County  
 PERMIT NO. 19-010-04-0 Humboldt Acres unit 2  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	10	10
GRAVEL		10	25	15
CLAY, GRAVEL		25	35	10
GRAVEL, SAND		35	70	35
CLAY, GRAVEL	x	70	105	35
GRAVEL, CLAY		105	120	15
SAND		120	125	5
SAND CLAY, GRAVEL	x	125	135	10
CLAY, GRAVEL		135	180	45

8. WELL CONSTRUCTION  
 Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)  
 From 0 To 180  
105/8 Inches Feet Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>63/8</u>		<u>.188</u>	<u>-1</u>	<u>180</u>

Perforations:  
 Type perforation MILL SLOT  
 Size perforation FACTORY  
 From 155 feet to 175 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 FT  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 30 feet to 180 feet

9. WATER LEVEL  
 Static water level 75 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality good

Date started 5-8 1997  
 Date completed 5-9 1997

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name AAA Drilling and Pump/Graco Contractor  
 Address 3359 Last Chance Rd. Contractor  
Elko, NV 89801  
 Nevada contractor's license number issued by the State Contractor's Board. 0038169  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 2053  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date 5-9-97