

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28036

1. OWNER New Beginning Christian Church ADDRESS AT WELL LOCATION 134 Esmeralda Dr Washoe, New Washoe City 89706  
 MAILING ADDRESS 134 Esmeralda Dr New Washoe City NV 89706  
 2. LOCATION SW 1/4 SW 1/4 Sec. 32 T. 17 S. R. 20 E Washoe County  
 PERMIT NO. 61501 Issued by Water Resources Parcel No. 050-411-22 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Blow Sands coarse</u>		<u>0</u>	<u>65</u>	<u>65</u>
<u>Gravels</u>				
<u>Coarse Gravels</u>		<u>65</u>	<u>129</u>	<u>64</u>
<u>Brown Clay</u>		<u>129</u>	<u>132</u>	<u>3</u>
<u>Medium Hard Granite</u>		<u>132</u>	<u>175</u>	<u>43</u>
<u>Very Hard Granite w/ Fracture XL</u>		<u>175</u>	<u>215</u>	<u>40</u>

8. WELL CONSTRUCTION  
 Depth Drilled 215 Feet Depth Cased 215 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 1/4 Inches To 6.5 Feet  
9 1/8 Inches 6.5 Feet 215 Feet  
 Inches Feet Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 3/8</u>	<u>13.088</u>	<u>.188</u>	<u>0</u>	<u>215</u>

 Perforations:  
 Type perforation Millslot  
 Size perforation 3 x 3/32  
 From 275 feet to 215 feet  
 From MD feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 55  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 65 feet to 215 feet

9. WATER LEVEL  
 Static water level 70 feet below land surface  
 Artesian flow 35 G.P.M. 35 P.S.I.  
 Water temperature Cold °F Quality Good

Date started 3-27, 1996  
 Date completed 3-29, 1996

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	<u>35</u>	<u>40</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A.E.H. Pump Company Contractor  
 Address 5551 Hwy 50 E #3 Contractor  
Carson City NV 89701  
 Nevada contractor's license number 31839 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
 Signed Michael J. Hall  
 By driller performing actual drilling on site or contractor  
 Date 3-29-96