WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69450
Permit No. 56922T
Basin 083

NOTICE OF INTENT NO. 33324

1. OWNER Story Co. Properties
MAILING ADDRESS 1580 Twin Oaks Road
Reno, NV. 89571

ADDRESS AT WELL LOCATION All-Lite
Aggregate, Lockwood Canyon

2. LOCATION NW ¼ NW ¼ Sec. 35 T. 19 N/S R. 21 E. Story County

PERMIT NO. 56922T (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & Boulders		0	55	55'
Gray Clay		55'	62	
Gray Volcanic Rock & Clay		62	78	
Gray Volcanic Rock Crevises		78	100'	22'
Brown Volcanics.		100	105'	5'
Black & Gray Volcanics		105'	159'	54'
Hard Gray Volcanics		159'	170'	11'
Gray Clay & Volcanic Rock		170'	210'	40'
Black Crevised Volcanic		210	226'	
Very Hard Dense Volcanic Rock		226'	265	
Med Hard Black Volcanic Rock		265	272'	
Hard Crevised Volcanic Rock.		272'	280'	
Black Med. Hard. Crevised Volcanic Rock & Clay		280	296'	
Hard Gray Volcanics		296	332'	
Light Gray Clay.	?	332	335'	3'
" " Volcanics		335	370'	35'
Gray Stickey Clay		370	375'	5'
Black & Red Volcanics		375	404'	
Gray Stickey Clay		404	405'	1

Date started May 20, 1996
Date completed June 4, 1996

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
250+ GPM	From 400' ft	
for 8 Hrs.		
Test -		
Pumped 180 GPM	From	
176 ft	For 2 Hrs.	

8. WELL CONSTRUCTION
Depth Drilled 405' Feet Depth Cased 405' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 3/4 Inches	0 Feet	405' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.250	+18"	405'

Perforations:
Type perforation Factory
Size perforation 3/16 X 3" Double Row
From 105' feet to 125 Screen
From 125' feet to 175 PREF feet
From 175' feet to 195 Screen feet
From 195 feet to 385 PREF feet
From 385 feet to 405 Screen feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 105'
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 105' feet to 405' feet

9. WATER LEVEL
Static water level 18 feet below land surface
Artesian flow NA G.P.M. P.S.I.
Water temperature 63 °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Leach Drilling Inc. (Contractor)
Address PO Box 599 (Contractor)
Silver Springs NV. 89429

Nevada contractor's license number issued by the State Contractor's Board 0031841

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740

Signed Nathaniel L. Leach
By driller performing actual drilling on site or contractor

Date July 3/96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627